

5 Day Written Report (Effluent Exceedance)

Facility Name : Nampa, City of - Nampa WWTP

Permit :

ID0022063 (POTW IP) ▾

Identify the pollutant (s) that exceeded limit(s):

- Ammonia, total as N
- Chlorine, total residual

Date of Incident:

05/09/2020

Start of Incident:

05/09/2020

End of Incident (if available):

05/10/2020

Start Date Time:

7:15 AM

End Date Time (if available):

7:15 AM

Discharge to waters of the US?

Yes No

Incident description and cause of noncompliance: 5/8/2020 our Digester gasket failed causing digester to drain on the ground causing high concentrations of ammonia into our system. A 24 hour composite was ran on May 9th showing an exceedance to our permit in Ammonia and Total Residual Chlorine. This exceedance was a 1 day event.

Estimated time noncompliance is expected to continue if it had not been corrected: (MM/DD/YYYY) 05/09/2020

Identify all steps taken or planned to reduce, eliminate, prevent reoccurrence of noncompliance: Working with consultants, contractors and manufacture to find out why this door failed. Training employee on importance of sampling of permit limits.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on the inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Check to certify you have read the above language and abide by the language and terms

Name:

Signature Date: