



Nampa Wastewater Division

340 W. Railroad Street, Nampa, Idaho 83687-1741
(208) 468-5840, FAX 467-9194

July 3, 2017

Idaho Dept. of Environmental Quality
Attn: Ms. Maria Lopez
950 W. Bannock Ste. 900
Boise, ID 83702

RE: Permit ID-002206-03

Dear Ms. Lopez,

On June 28, 2017 the City of Nampa's Wastewater Treatment Plant (WWTP), permit no. ID-002206-03 exceeded the E. Coli Bacteria Maximum Daily Limit of 576 #/100 ml. The Lab results for June 28, 2017 were received on June 29, 2017 at 1:40 PM showing an E. Coli Bacteria of 648.8 #/100ml.

After receiving the results from the Lab, the wastewater staff took another sample to verify the WWTP was back within Permit Limits for E. Coli Bacteria. The staff verified there was no disruption in the operation of the disinfection system, as well as, reviewed plant data to find nothing unusual which would cause the exceedance for E. Coli Bacteria.

On June 30, 2017, the results from the extra sampling came in at 135.4 #/100 ml. Normal scheduled sampling resumed on June 30, 2017. The results from that sampling came in on July 1, 2017 with a reading of 143.9 #/100 ml. The WWTP is fully back within compliance and the cause of the high E. Coli Bacteria reading is unknown.

Thank you,

A handwritten signature in blue ink, appearing to be "A Zimmerman", is written over a horizontal line.

Andy Zimmerman
City of Nampa
Wastewater Superintendent
208-468-5843

NAMPA*Proud*



Nampa Wastewater Division

340 W. Railroad Street, Nampa, Idaho 83687-1741
(208) 468-5840, FAX 467-9194

July 3, 2017

US EPA Region 10
Attn: NPDES Permits Unit Manager
1200 Sixth Ave, STE 900
OWW-191
Seattle, WA 98101-3104

RE: Permit ID-002206-03

Dear NPDES Permit Unit Manager,

On June 28, 2017 the City of Nampa's Wastewater Treatment Plant (WWTP), permit no. ID-002206-03 exceeded the E. Coli Bacteria Maximum Daily Limit of 576 #/100 ml. The Lab results for June 28, 2017 were received on June 29, 2017 at 1:40 PM showing an E. Coli Bacteria of 648.8 #/100ml.

After receiving the results from the Lab, the wastewater staff took another sample to verify the WWTP was back within Permit Limits for E. Coli Bacteria. The staff verified there was no disruption in the operation of the disinfection system, as well as, reviewed plant data to find nothing unusual which would cause the exceedance for E. Coli Bacteria.

On June 30, 2017, the results from the extra sampling came in at 135.4 #/100 ml. Normal scheduled sampling resumed on June 30, 2017. The results from that sampling came in on July 1, 2017 with a reading of 143.9 #/100 ml. The WWTP is fully back within compliance and the cause of the high E. Coli Bacteria reading is unknown.

Thank you,

A handwritten signature in blue ink, appearing to read "Andy Zimmerman".

Andy Zimmerman
City of Nampa
Wastewater Superintendent
208-468-5843

NAMPA Proud



Nampa Wastewater Division

340 W. Railroad Street, Nampa, Idaho 83687-1741
(208) 468-5840, FAX 467-9194

July 3, 2017

Idaho Dept. of Environmental Quality
Attn: Mr. Todd Crutcher, Engineering Manager
1445 N. Orchard
Boise, ID 83706-2239

RE: Permit ID-002206-03

Dear Mr. Crutcher,

On June 28, 2017 the City of Nampa's Wastewater Treatment Plant (WWTP), permit no. ID-002206-03 exceeded the E. Coli Bacteria Maximum Daily Limit of 576 #/100 ml. The Lab results for June 28, 2017 were received on June 29, 2017 at 1:40 PM showing an E. Coli Bacteria of 648.8 #/100ml.

After receiving the results from the Lab, the wastewater staff took another sample to verify the WWTP was back within Permit Limits for E. Coli Bacteria. The staff verified there was no disruption in the operation of the disinfection system, as well as, reviewed plant data to find nothing unusual which would cause the exceedance for E. Coli Bacteria.

On June 30, 2017, the results from the extra sampling came in at 135.4 #/100 ml. Normal scheduled sampling resumed on June 30, 2017. The results from that sampling came in on July 1, 2017 with a reading of 143.9 #/100 ml. The WWTP is fully back within compliance and the cause of the high E. Coli Bacteria reading is unknown.

Thank you,

A handwritten signature in blue ink, appearing to read "Andy Zimmerman", is written over a horizontal line.

Andy Zimmerman
City of Nampa
Wastewater Superintendent
208-468-5843

NAMPA*Proud*